



Los Angeles Community College District Design Standards

City • East • Harbor • Mission • Pierce • Southwest • Trade-Technical • Valley • West

LACCD Facilities Design Standards– Toilet and Urinal Campus Facility Standards Cross- Reference Div. 22

GENERAL - ITEMS ARE NUMBERED FOR EASE OF REFERENCE

1. Provide permanent power and water to each fixture.
2. All restroom shall be ADA compliant.
3. The flushing volume for the toilet shall not exceed 1.28 gallon per flush.
4. The flushing volume for the urinal shall not exceed 0.125 gallon per flush.
5. All flushing valve shall be automatic sensor activated type. The Power source shall be hard wired.
6. The fixtures color shall be white and material of vitreous china or stainless steel.
7. The fixtures shall be easy to install and replace by using standard/none-proprietary tools
8. All surface and finish of the fixtures shall withstand commercial usage and harsh chemical treatment during cleaning and maintenance yet vandal resistant.
9. The toilet shall be wall hung elongated type, unless directed by college, for easy maintenance.
Provide backing in wall.
10. Urinal shall have 17" minimum width with extended side
11. No filters or cartridges in all fixtures which require regular maintenance or replacement.
12. Provide gray water to toilet and urinal where available.
13. Provide access panel to all plumbing devices in the wall.